

Inwood Farm Test Pit Results 3-21-2011

Following are the results of 29 test pits, dug on March 21st, 2011

HOLE #	FINDINGS
Hole 1	7 feet of filled material, original topsoil layer 7 feet below grade.
Hole 2	8 feet of filled material, original topsoil layer 8 feet below grade.
Hole 3	9 feet of filled material, original topsoil layer 9 feet below grade.
Hole 4	3 feet of filled material, original topsoil layer 3 feet below grade.
Hole 5	no fill material.
Hole 6	9 feet of filled material, original topsoil layer 9 feet below grade.
Hole 7	8 feet of filled material, original topsoil layer 8 feet below grade.
Hole 8	6 feet of filled material, original topsoil layer 6 feet below grade.
Hole 9	4 feet of filled material, original topsoil layer 4 feet below grade.
Hole 10	8 feet of filled material, original topsoil layer 8 feet below grade.
Hole 11	8 feet of blacktop fill, unable to dig after 8 feet due to continuous vein of compacted blacktop.
Hole 12	no unexpected filled material.
Hole 13	3 feet of filled material, original topsoil layer 3 feet below grade.
Hole 14	6 feet of filled material, original topsoil layer 6 feet below grade.
Hole 15	no unexpected filled material.
Hole 16	no unexpected filled material.
Hole 17	8 feet of filled material, original topsoil layer 8 feet below grade.
Hole 18	no unexpected filled material.
Hole 19	4 feet of filled material, original topsoil layer 4 feet below grade.
Hole 20	3 feet of filled material, original topsoil layer 3 feet below grade.
Hole 21	2 feet of filled material, original topsoil layer 2 feet below grade.
Hole 22	2 feet of filled material, original topsoil layer 2 feet below grade.
Hole 23	no unexpected filled material.
Hole 24	2 feet of filled material, original topsoil layer 2 feet below grade.
Hole 25	4 feet of filled material, original topsoil layer 4 feet below grade.
Hole 26	7 feet of filled material, original topsoil layer 7 feet below grade.
Hole 27	7 feet of filled material, original topsoil layer 7 feet below grade.
Hole 28	7 feet of filled material, original topsoil layer 7 feet below grade.
Hole 29	4 feet of filled material, original topsoil layer 4 feet below grade.

Sample Photos



Figure 1--Equipment



Figure 2--Hole 6



Figure 3--Hole 9



Figure 4--Hole 10

Note bricks and pieces of metal along with rock.



Figure 5--Hole 11



Figure 6--Hole 11



Figure 7--Hole 11



Figure 8--Hole 14



Figure 9--Hole 15



Figure 10--Hole 26

Drawing of Excavation Map

